

Airflow DataGuard 5.0 AFX AC w/Setpoint Full Control Monitored Points List

Status	Meters
Device Communications	Return Air Temperature
Cooling Mode	Supply Air Temperature
Heating Mode	PC-ECWS Water Temperature
Dehumidifying Mode	Return Air Humidity
Humidifying Mode	PC-ECWS Valve % Open
Airflow Status	Humidifier Valve % Open
Clogged Filter Status	Hot Water Valve % Open
Water Detector Status	Blower Run Time
Compressor #1 Low Head Pressure	Humidifier Run Time
Compressor #2 Low Head Pressure	Compressor #1 Run Time
Water Flow Status	Compressor #2 Run Time
Firestat Status	
Smoke Monitor Status	<u>Setpoints</u>
Humidifier Water Level	Cooling Setpoint
Compressor #1 High Head Pressure	Heating Setpoint
Compressor #2 High Head Pressure	Dehumidification Setpoint
Return Air Temperature High	Humidification Setpoint
Return Air Temperature Low	
Hot Water Temperature High	<u>Control</u>
Hot Water Temperature Low	Humidity Setpoint Control
Humidity High Status	Temperature Setpoint Control
Humidity Low Status	Off/Standby/On
Power Loss Status	Inhibit Control
Blower Status	Zone Number
Heat Stage #1	ID Number
Heat Stage #2	Initial Status Primary Schedule
Humidifier Run Status	Initial Status Secondary Schedule
Compressor #1 Liquid Line	Manual Override
Compressor #1 Run Status	AC Control Standby Alarm
Compressor #2 Liquid Line	AC Control Off Alarm
Compressor #2 Run Status	Control State
Common Status	
Return Air Temp Sensor Fail	
Hot Water Temp Sensor Fail	
Return Air Humidity Sensor Fail	