

DataAire Dart AC w/Full Control Monitored Points List

Status	Meters
Device Communications	Temperature
Dehumidification	Relative Humidity
Humidification	Number of Cooling Stages On
Energy Saver	Number of Heating Stages On
Manual Override	Chilled Water Valve Open
Water Detected Under Floor	Chilled Water Source
Air Flow	Compressor #1 Runtime
Filter Status	Compressor #2 Runtime
Humidifier Failure	Heater #1 Runtime
Low Voltage Status	Heater #2 Runtime
Firestat Status	Heater #3 Runtime
Compressor Short Cycle Warning	Humidifier Runtime
Power Failure Restart	Evaporative Blower Runtime
Humidity Sensor	Condenser Runtime
Temperature Sensor	Dehumidifier Runtime
Scheduled Maintenance Due	Energy Saver Cooler Runtime
Compressor #1 High Pressure Fail	Chilled Water Cooling Runtime
Compressor #1 Low Pressure Fail	
Compressor #2 High Pressure Fail	<u>Setpoints</u>
Compressor #2 Low Pressure Fail	Humidity Setpoint
Smoke Detected Condition	Temperature Setpoint
Water Flow Status	
Discharge Temperature Sensor	<u>Control</u>
High Return Air Temp Condition	Humidity Setpoint Control
Low Return Air Temp Condition	Temperature Setpoint Control
High Humidity Condition	Off/Standby/On
Low Humidity Condition	Inhibit Control
Main Fan	Zone Number
Local Alarm #1	ID Number
Local Alarm #2	Initial Status Primary Schedule
Local Alarm #3	Initial Status Secondary Schedule
Local Alarm #4	Manual Override
Standby Pump On	AC Control Standby Alarm
UPS Power On	AC Control Off Alarm
Unit On/Off	Control State
	Zone Inhibit Control State