

MGE
Monitored Points List

Status	Meters
ACQ FAULT	Volts 12 Input
Battery Time	Volts 23 Input
Battery Life	Volts 31 Input
System Abnormal	Volts1N Inverter
Malfunction	Volts2N Inverter
Unsafe Operation	Volts3N Inverter
On Battery	Volts 12 Load
EPO	Volts 23 Load
Static Switch Inverter	Volts 31 Load
	Volts Battery
	kW p1
	kW p2
	kW p3
	kVA p1
	kVA p2
	kVA p3
	kW total
	kVA total
	% Inverter Load
	Power Factor
	Amps 1 Input
	Amps 2 Input
	Amps 3 Input
	Amps 1 Load
	Amps 2 Load
	Amps 3 Load
	Amps Battery
	Freq Input
	Freq Inverter
	Freq Mains 2
	Freq Load